

Fire Department Connection

Per NFPA 25 v2023: 13.8.1

Answer each line item with Y = yes, N = no or NA = not applicable

Location of Fire Department Connection:

12 columns = 3 YEARS

Date:												
Visible and accessible												
Couplings or swivels are not damaged and rotate smoothly												
Plugs or caps are in place and undamaged												
If caps or plugs are missing, interior is clear of obstructions												
Gaskets are in place												
Identification signs are in place												
Check valve is not leaking												
Automatic drain valve is in place and operating properly												
Visible piping to fire department connection is undamaged												



For more information and additional checklists, scan the QR code.

Contact a Summit Fire & Security expert if you need assistance.
www.summitfiresecurity.com